

---

To: TAL-CO Building Innovations

---

Date: August 29th, 2016

Reference: Tomlinson – New Office

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

---

Additions/Modifications:

1. Refer to 'Issued for Pricing' drawing set (attached).
2. Walker duct system two be c/w two ducts (one for power distribution and one for communication). Typical details show single duct layout.

Clarifications

3. All duct banks under main building and test facility to be concrete encased.
4. Lighting fixtures: Proposed equivalent alternate fixtures are at the discretion of the owner. Provide all shop drawings, proposed layouts and photometric calculations with tender submission, for review by owner and Engineer. Samples may be requested by owner, during review with successful bidder.
5. Site plan and below grade drawings (ES1, E010 & E011) to be read in conjunction.
6. Electrical drawings to be read in conjunction with Security/IT and A/V drawings provided by Nooga.

END OF ADDENDUM