

---

To: TAL-CO Building Innovations

---

Date: September 14th, 2016

Reference: Tomlinson – New Office

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

---

**AE3.1 General Additions/Clarifications**

- .1 Clarification – Note Number 10 on the Distribution feeder Schedule of the single line diagram should be updated to read “4x (3-350MCM RWU90 XLPE+GND in 78mmC)” in lieu of the note shown as “3-350MCM RWU90 XLPE+GND in 78MMC)”

END OF ADDENDUM