



- DRAWING NOTES:**
- ◇ PROVIDE SIDE LIT LED EXIT SIGN C/W DIRECTIONAL ARROWS AS INDICATED. ALL ASSOCIATED HARDWARE. EXIT SIGN TO BE TIED INTO EMERGENCY LIGHTING CIRCUIT.
 - ◇ LIGHT FIXTURE TO BE TIED INTO EMERGENCY LIGHTING CIRCUIT AND REMAIN UNSWITCHED AT ALL TIMES.
 - ◇ PROVIDE LIGHTING FIXTURE, ALL CONDUIT, WIRING AND ASSOCIATED HARDWARE.
 - ◇ FIRE ALARM PANEL, REFER TO RISER DIAGRAM FOR FURTHER DETAILS.
 - ◇ PROVIDE FIRE ALARM DEVICE AS INDICATED C/W ALL CONDUIT, WIRING AND ASSOCIATED HARDWARE.
 - ◇ LIGHTING TO BE CONTROLLED BY BAS BUILDING AUTOMATION SYSTEM.
 - ◇ LOW VOLTAGE LIGHTING CONTROL PANEL TO BE MOUNTED AS HIGH AS POSSIBLE. LOCATION TO BE DETERMINED ON-SITE.

1 GROUND FLOOR – R.C.P.
E101 SCALE 1:100

An exact copy of all working documents including, without limitation, the original of the present document or plan is kept on file by J.R.P. Engineering. Any modification carried out to this document or plan or to accompanying documents without written authorization by the engineer is prohibited.

Authorized modifications must be signed and sealed by an engineer and this engineer will be completely responsible for these modifications. J.R.P. Engineering is not and will not be responsible for the consequences of these modifications or for modifications carried out without its consent.

No	DESCRIPTION	DATE
2	ISSUED FOR ARCH. REVISIONS, & FOUNDATION/ SLAB COORDINATION	OCT. 01 2016
1	ISSUED FOR BUILDING PRICING	AUGUST 29 2016
0	ISSUED FOR BUILDING PERMIT	AUGUST 5 2016

REVISIONS	

client:
TOMLINSON
5597 POWER RD
OTTAWA, ON
K1G 3N4

project:
TOMLINSON
NEW BUILDING
CITIGATE, OTTAWA

drawing title:
R.C.P
GROUND FLOOR

scale:	AS SHOWN	drawn by:	M.G
designed by:	M.G	reviewed by:	J.R.P.
approved by:	J.R.P.	date:	APR 2016

project no.:	100-16L	drawing no.:	E-101
revision:	0		