



R.W. TOMLINSON - NEW HEAD OFFICE

TAL-CO Building Innovations
1341-2 Coker Street
Greely, Ontario K4P 1A1
Tel: 613-821-3959
Fax: 613-821-2938

Issue date: 17-Mar-17
Revision date: N/A
Revision #: N/A

CLARIFICATION #3 – Lot 3A

The following modifications and clarifications are to be accounted for on this project. As well, when entering into the Form of Agreement to do the work, they shall become a part thereof.

Instruction/Clarifications:

Please be advised that Clarification #3 Lot 3A has been issued for the above-mentioned project.

- As per Spec Section 06 40 00 Page 5, the intent is to use Grade HGS Plastic Laminate on Exposed Surfaces, whereas Grade HGL Plastic Laminate Veneer for Unexposed faces only.
- As per Spec 06 40 00 2.07.7, "Plywood" is intended to be **Veneer Core Plywood** for use on all millwork construction including doors, drawer fronts etc..

Reminder: It is your responsibility to consult ALL documents, drawings, sketches, Clarifications, Addenda, and Supplemental Instructions.

For questions or further information, please contact the office by e-mail at info@tal-co.com.

End of Clarification No.3 – Lot 3A