



QUADRANT
ENGINEERING LIMITED, CONSULTING ENGINEERS
107 PRETORIA AVE., OTTAWA, ONTARIO, K1S 1W8
TEL. (613) 567-1487 FAX (613) 567-1493
E-Mail: mail@quadrantengineering.ca

ALL LIGHT SWITCHES TO BE MOUNTED 1100mm AFF. -
1200mm AFF. -
ALL LIGHTS TAKEN FROM TOP OF FINISH FLOOR LEVEL. AFF TO CENTER OF OUTLET BOX.

ALL F/A PLT. SWITCHES TO BE MOUNTED 1200mm AFF. -
1200mm AFF. -
ALL LIGHTS TAKEN FROM TOP OF FINISH FLOOR LEVEL. AFF TO CENTER OF OUTLET BOX.

EXACT LOCATION OF EQUIPMENT SUBMITTED TO COORDINATION WITH MECHANICAL.

ALL ENTRY CONDUNIT TO BE C/W PULL ROPE.

GENERAL NOTES:

PROBLEM
SOUTHWAY INN
RETRO-FIT
RETIREMENT HOME

Electrical
Partial Third Floor
Plan Lighting
(Typ. 3RD TO 6TH)