

1. CONTRACTOR TO REFER TO ARCHITECTURAL, MILLWORK & ELEVATIONS DRAWINGS FOR THE EXACT PLACEMENT & MOUNTING HEIGHTS FOR EACH PLACE OF KITCHEN EQUIPMENT.
2. CONTRACTOR TO VERIFY PRIOR TO ROUTING IN KITCHEN EQUIPMENT ALTHOUGH THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE EXACT PLACEMENT, MOUNTING, DRAWINGS FOR THE EXACT PLACEMENT & MOUNTING HEIGHTS FOR EACH PLACE OF KITCHEN EQUIPMENT.
3. BEFORE ROUTING-IN, CONTRACTOR TO CONFIRM WITH KITCHEN EQUIPMENT SUPPLIERS SPECIFICATIONS (IN REFERENCE TO ELECTRICAL EQUIPMENT LIST) EXACT CONNECTION REQUIREMENTS FOR EACH PLACE OF KITCHEN EQUIPMENT (I.e. DIRECT CONNECTED OF PLUG-IN).
4. CONTRACTOR TO NOTIFY ELECTRICAL ENGINEER OF ANY DISCREPANCIES FOUND BETWEEN KITCHEN SUPPLIER & ELECTRICAL ENG..
5. CONTRACTOR TO INCLUDE IN ITS PRICE:
CAB-TIE AND MALE CAP C/W CONNECTION TO EQUIPMENT (MADE BY CONTRACTOR) FOR ALL "PLUG-IN" EQUIPMENT SHOWN ON THE KITCHEN BEFORE ROUTING-IN, FINAL CONNECTIONS TO BE CONFIRMED.
6. PROVIDE A 6'-0" WHIP MINIMUM (FROM J-BOX) FOR INSTALLED KITCHEN EQUIPMENT REQUIRING PLUG-IN CONNECTION - TO BE C/W "CORB" SET.
7. NO FLOOR MOUNTING OF DEVICES (I.e. RECEPTACLES & J-BOXES) PERMITTED MINIMUM OF: CONNECTION OF KITCHEN EQUIPMENT TO BE A
- 12" AFF.

ALL ELECTRICAL DEVICES LOCATED UNDER KITCHEN HOODS TO SHUT DOWN UPON ACTIVATION OF FIRE SUPPRESSION SYSTEM.
(SEE PANEL LEGENDS FOR RELAY REQUIREMENTS TO CCT. BKRS.)

1. INTERLOCKING OF FIRE SUPPRESSION SYSTEM BY DIV.15, INTERLOCKING OF FIRE SUPPRESSION SYSTEM WITH FIRE ALARM SYSTEM BY DIV.16.
2. PROVIDE 120V DIRECT CONNECTION TO HOOD SUPPRESSION SYSTEM EXACT LOCATION TO BE COORDINATED ON SITE.
3. PROVIDE F/A ZONE FOR HOOD SUPPRESSION SYSTEM.



<p>WORKING NAME:</p> <p>ELECTRICAL</p> <p>PARTIAL GROUND</p> <p>FLOOR PLAN –</p> <p>KITCHEN POWER</p>	<p>VERSION:</p> <p>DATE:</p>	<p>SHEET:</p> <p>E18</p>
--	--	--

REFER TO MECH. DWGS. FOR EXACT LOCATION OF FREEZER DRAIN
JOB FOR HEAT TRACE OF EVAP FREEZER DRAIN PIPE