



QUADRANT
 ELECTRICAL DIVISION, CONSULTING ENGINEERS
 1500 WEST 10TH AVENUE, SUITE 100
 DENVER, CO 80202
 TEL: (303) 733-4400 FAX: (303) 733-4403
 E-MAIL: info@quadranteng.com

S.J. LAWRENCE
 ARCHITECT INCORPORATED
 18 BARCLAY STREET, SUITE 200, DENVER, CO 80202
 TEL: (303) 733-4400 FAX: (303) 733-4403
 E-MAIL: sjlawrence@sjl.com

DATE: 09 JULY 20/15
REVISION: 01
 01: ISSUED FOR PERMIT
 02: APR 16/15 RE-ISSUED FOR PERMIT
 03: JUN 22/15 PROGRESS ISSUE
 04: JUN 22/15 PROGRESS ISSUE
 05: JULY 20/15 ISSUED FOR PERMIT

REVISIONS:

NO.	DATE	REVISION
01	07/20/15	ISSUED FOR PERMIT
02	04/16/15	RE-ISSUED FOR PERMIT
03	06/22/15	PROGRESS ISSUE
04	06/22/15	PROGRESS ISSUE
05	07/20/15	ISSUED FOR PERMIT

ALL LIGHT SWITCHES TO BE MOUNTED 1100mm AFT. FINISH FROM TOP OF FINISH FLOOR LEVEL. "MFT" TO CENTER OF OUTLET BOX.
ALL F/A FULL STATIONS TO BE MOUNTED 1200mm AFT. - 1200mm HEIGHT TAKEN FROM TOP OF FINISH FLOOR LEVEL. "MFT" TO CENTER OF OUTLET BOX.
EXACT LOCATION OF EQUIPMENT WITH REFERENCE TO COORDINATION WITH MECHANICAL TO BE C/W FULL RISE.
ALL GPNY CONDUIT TO BE C/W FULL RISE.
GENERAL NOTES:

SOUTHWAY INN
 RETRO-FIT
 RETIREMENT HOME

PANEL DETAILS
 SHEET 1

E23

DATE: 09 JULY 20/15
REVISION: 01

REVISIONS:

NO.	DATE	REVISION
01	07/20/15	ISSUED FOR PERMIT
02	04/16/15	RE-ISSUED FOR PERMIT
03	06/22/15	PROGRESS ISSUE
04	06/22/15	PROGRESS ISSUE
05	07/20/15	ISSUED FOR PERMIT