



Dovercourt Recreation Centre Addition 411 Dovercourt Ave, Ottawa, ON

TAL-CO Building Innovations
1341-2 Coker Street
Greely, Ontario K4P 1A1
Tel: 613-821-3959
Fax: 613-821-2938

Issue date: 24-Oct-17
Revision date: N/A
Revision #: N/A

POST TENDER ADDENDUM #1 - NOTIFICATION

The following modifications and clarifications are to be accounted for when tendering on this potential contract. As well, when entering into the Form of Agreement to do the work, they shall become a part thereof.

Instruction/Clarifications:

Please review the additional drawings and information as noted below and resubmit revised pricing.

- Elevation Drawings R4 – Curtain Wall A3.01, A3.02, A3.03

Details:

Curtain Wall (please see attached A3.01, A3.02, A3.03 drawings)

- Addition of a new mullion on W2, W3, W4, W5. This will reduce the mullion centre measures and allow for more mullion height
- Replacement of Alumicor 2200 with Alumicor 2600.
- Use 133.4mm mullion depth for all exterior curtain wall.

- *We believe these changes should eliminate the need to use steel reinforcing inside any of the mullions. If the supplier finds otherwise, steel reinforcing can be added as required to make the window load requirements. (We have reviewed against 20psf loads)*

Please see below for answers for other questions:

1) Can you please clarify what type of glass is required for GL-1? Is it just tempered single glass or tempered laminated glass? If tempered laminated, how thick is the glass and what is the thickness of the interior PVB layer to be?

Tempered and Laminated. As per engineered requirements for size of lights. Please keep in mind impact is highly probable as this is a gym.

Interior panes of exterior glazing should also be tempered and laminated.

2) *Is the aluminum supplier responsible to supply the frames tagged ALF-1?*

Yes. These should match the other AFL series frames.

3) *Is there any indication of what the color code of the Duranar paint finish is on the exterior caps?*

This is to match the existing (see 2014 addition at the rear of the building).

4) *Is Door 221.2 to be painted to match exterior finish of curtain wall or is it to be #14 clear anodized?*

The exterior face is to match the Duranar finish.

Post Tender Addendum #1 is also available on the TAL-CO website: www.tal-co.com

Revised pricing is required by Friday October 27, 2017.

Please direct all questions and inquiries to the office via e-mail at info@tal-co.com.

End of Post Tender Addendum No. 1