

1- LIGHTING CONTROL:
 - IN ROOMS WITH DAYLIGHT SENSOR, FIXTURE SHALL DIM ACCORDING TO AVAILABLE DAYLIGHT.
 - IN CORRIDORS, WASHROOMS AND STAIRS LIGHTING IS CONTROLLED TROUGHT OCCUPANCY SENSOR.
 IN TECHNICAL ROOMS, STORAGE AND OTHER ROOM LIGHTING IS CONTROLLED TROUGHT OCCUPANCY SENSOR. IN OTHER ROOMS, LIGHTING IS CONTROLLED TROUGHT A SWITCH AND A OCCUPANCY SENSOR. (MANUAL ON/AUTO OFF)

- 2- ALL THE LIGHTING DEVICES UNDER THE HATCHED ZONE ARE SHOWN ON THE DRAWING E-102.

- 1 CEILING MOUNTED AND CENTERED.
- 2 TO BE INSTALLED IN THE ELEVATOR SHAFT.
- 3 PROVIDE LOCKABLE METAL BOX OVER THE DIMMERS.
- 4 FIRE ALARM TRANSMISSION EQUIPMENT.

[illegible]

PAGEAU
MOREL
www.pageaumorel.com
Gatineau



J.L. Richards
ENGINEERS • ARCHITECTS • PLANNERS
www.jlrichards.ca

Seal



MAISON DE
DE LA FRANCOPHONIE D'OTTAWA
2720 RICHMOND ROAD, OTTAWA

Title

ELECTRICAL - MULTIDISCIPLINARY
GROUND FLOOR
NEW LAYOUT

Drawn by :	F.BR.	Project n°:	7342-001-000
Design by :	J.RI.	Date :	2018-06-01
Verified by :	M.L.E.	Scale :	1/8" = 1'-0"

Drawing n°

Revision

THIS DRAWING SHALL NOT BE USED FOR
CONSTRUCTION OR INSTALLATION
PURPOSES.

MODIFIED

E-101

0