

1. ALL CONDUITS TO BE CONCEALED UNLESS OTHERWISE SPECIFIED.
2. PROVIDE TEMPER STAINER PLUGS IN THE TWO (2) DAYCARE AREA.
3. LIGHTING CONTROL:
 - IN ROOMS WITH DAYLIGHT SENSOR, FIXTURE NEAR WINDOW SHALL DIM ACCORDING TO AVAILABLE DAYLIGHT.
 - IN CORRIDORS, WASHROOMS AND STAIRS LIGHTING IS CONTROLLED THROUGH OCCUPANCY SENSOR.
 - IN TECHNICAL ROOMS, STORAGE AND OTHER ROOM LIGHTING IS CONTROLLED THROUGH OCCUPANCY SENSOR.
 - IN OTHER ROOMS, LIGHTING IS CONTROLLED THROUGH A SWITCH AND AN OCCUPANCY SENSOR, (MANUAL ON/AUTO OFF)
4. UNLESS NOTED OTHERWISE, ALL LIGHTING IS CONNECTED ON ELECTRICAL PANEL P-65, C-23
5. UNLESS NOTED OTHERWISE, ALL NORMAL SERVICES ARE CONNECTED ON ELECTRICAL PANEL P-65.

A- JUNCTION BOX IN CEILING SPACE FOR AUTOMATIC DOOR SYSTEM C/W CONDUIT AND PUSH BUTTONS. INSTALL A TEMPORIZED RELAY ON AUTOMATIC DOORS. COORDINATE EXACT LOCATION OF THE PUSH BUTTONS WITH ARCHITECT.

- 1 TO BE INSTALLED IN THE CEILING.
- 2 ELECTRICAL CONNECTION FOR FAN ON THE ROOF.
- 3 COORDINATE EXACT HEIGHT AND LOCATION WITH OWNER. PLUG IS APPROXIMATELY AT 72" AND DATA AT 60" FROM THE FLOOR.
- 4 SEE KITCHEN DETAIL.
- 5 COORDINATE EXACT HEIGHT AND LOCATION WITH OWNER.

[illegible]

A circular professional seal for a Licensed Professional Engineer in the Province of Ontario. The seal contains the text "LICENSED PROFESSIONAL ENGINEER" around the top and "PROVINCE OF ONTARIO" around the bottom. In the center, it reads "M.A. J. LECLERC" and "109155045". A blue ink signature is written across the bottom of the seal.

Title

ELECTRICAL - MULTIDISCIPLINARY
GROUND FLOOR
NEW LAYOUT FOR SEQUENCE 3

Drawing nº	Revision
------------	----------

MODIFIED

E-901

0



blascon - 6/1/2018 11:18 - O:\7342 2720 Richmond\001\000\IE-901(EM-M-GRD)_R00.dwg