

- 1- PERFORMANCE BASED SPECIFICATIONS.  
THIS DRAWING IS PRESENTED AS ADDITIONAL DESIGN CRITERIA.
- 2- UNLESS INDICATED OTHERWISE ALL THE SPRINKLERS SHALL BE STANDARD K FACTOR OF 5.6. REFER TO ELECTROMECHANICAL SPECIFICATIONS SECTION 21 10 00 FOR SPRINKLER HEAD REQUIREMENTS.
- 3- IN AREAS IMMEDIATELY ABOVE EQUIPMENT THAT PRODUCES LARGE AMOUNTS OF HEAT AND HIGH TEMPERATURES, OR WHERE MAXIMUM CEILING TEMPERATURES EXCEED 1000° (538°) SPRINKLERS WITH TEMPERATURE RATINGS IN ACCORDANCE WITH THE MAXIMUM CEILING TEMPERATURES OF TABLE 6.2.5.1 OF NFPA 13 SHALL BE USED.
- 4- SPRINKLERS OF INTERMEDIATE - AND HIGH-TEMPERATURE RATINGS SHALL BE INSTALLED IN SPECIFIED LOCATIONS AS REQUIRED BY THE NFPA 13 - 8.5.2. TABLE 10.007.2 (2) SPRINKLERS SHALL BE INSTALLED ON SITE WHEN THE FINAL LOCATION OF THE UNIT HEATER IS CONFIRMED.
- 5- THE SPRINKLERS INSTALLED IN HORIZONTAL COMBUSTIBLE CONCEALED SPACES WHERE THE DEPTH OF THE SPACE IS LESS THAN 26 in. (660 mm) FROM DECK TO CEILING, SHALL BE LISTED FOR SUCH USE.
- 6- DO NOT TAKE SCALE MEASUREMENT ON DRAWINGS. THE CONTRACTOR IS RESPONSIBLE FOR PERFORMING DIMENSIONAL AUDITS APPEARING ON THE DRAWINGS AND THE SITE CONDITIONS IN ORDER TO VERIFY THEIR ACCURACY.

- 1 FLOOR FLOW CONTROL & TEST STATION. SEE DETAIL FOR ACCESSORIES TO BE INSTALLED.
- 2 OPEN GRID ON PERIMETER OF T-BAR CEILING. PROVIDE UPRIGHT SPRINKLER HEADS ABOVE CEILING GRID AT SLAB LEVEL & PENDANT SPRINKLERS UNDER THE GRID FOR FLOOR COVERAGE.
- 3 PROVIDE AND INSTALL PROTECTIVE GUARD ON SPRINKLER HEAD.

[illegible]

### Revision

0