

BASEMENT

FIRE PROTECTION SYSTEM DIAGRAM

SCALE : N.T.S.

| ٧º | Date | Description |
|----|------------|-------------|
| 0 | 2018-06-01 | FOR TENDER |



MAISON DE DE LA FRANCOPHONIE D'OTTAWA

> MECHANICAL FIRE PROTECTION

SCHEDULES & DETAILS Project n°: 7342-001-000

Drawing n⁰

- 3" DOMESTIC WATER

FIRE PROTECTION BY DIVISION 21.

— 6" DOMESTIC WATER MAIN BY DIVISION 21

BACK FLOW PREVENTER.
SEE SPECIFICATIONS IN DIV.22 FOR DESCRIPTION

65 mm (2 1/2"Ø) HOSE OUTLET FOR BACKFLOW DEVICE FORWARD FLOW TEST (250 GPM MIN. EACH)
COORDINATE WITH DIVISION OF PLUMBING FOR PROPER DRAINAGE DISCHARGE

M-110

2018-06-01

1/8" = 1'-0"