

- 1- ALL EXISTING PIPING, THIS INCLUDES DW, DHW, VENTS, STORM AND SANITARY DRAINAGE AT CEILING LEVEL, TO REMAIN, SOME SECTIONS WILL REQUIRE SOME REPLACEMENT, SEE NEW LAYOUT.
- 2- ALL EXISTING UNDERGROUND SANITARY DRAINAGE WAS COMPLETED, FLOOR DRAINS ARE IN PLACE, ALL OTHER CONNECTIONS ABOVE GROUND ARE TO BE REMOVED, BASEMENT STOPPED AT LAST ELBOW BEFORE GOING UP TO GROUND FLOOR, SOME MAY BE REUSED, MOST ARE TO BE REDONE, SEE DRAWING.
- 3- SOME REMOVAL WILL BE REQUIRED AS INDICATED ON DRAWING, SOME SECTION OF PIPING IS DAMAGED OR HAS BEEN PULLED DOWN, THESE SECTIONS ARE TO BE REMOVED, RECYCLE EXISTING VALVES THAT HAVE ALREADY BEEN INSTALLED IF POSSIBLE, (BALL VALVES MOSTLY).
- 4- ALL EXISTING PIPE SUPPORTS WILL HAVE TO BE VERIFIED AND REPLACED WHERE NECESSARY, SOME MAY BE REUSED, BUT NOT MORE THAN 20% REPLACEMENT ON PIPING THAT REMAINS, ALL OTHER PIPE SUPPORTS NOT USED OR DAMAGED ARE TO BE REMOVED COMPLETELY.
- 5- FOR INFORMATION ONLY, PIPING MATERIAL FOR CONDENSATE DRAINAGE SHOWN ON DRAWING IS AS FOLLOWS. MAIN PIPING IS R/S PLASTIC PIPING AND SIDE BRANCHES ARE COPPER.
- 6- FOR INFORMATION ONLY, PIPING MATERIAL FOR STORM AND SANITARY

- 1 MAIN SANITARY LINE TO BE REPLACED IN PLACE. MAIN TO BE REPLACED BY 16" MAIN P.V.C. BRANCHES ARE TO BE REVISD TO SUIT NEW LAYOUT. SEE NEW LAYOUT FOR MODIFICATIONS TO BE MADE.
- 2 EXISTING PIPING TO BE CAPPED AT THE LOCATION INDICATED. CONTINUATION TO BE REMOVED UP TO WHERE INDICATED ON DRAWING.
- 3 EXISTING GAS LINE PART OF TEMPORARY HEATING LOOP. TO BE REMOVED WHEN WINTER HEATING IS NO LONGER REQUIRED. COORDINATE WITH GENERAL CONTRACTOR.
- 4 SECTIONS OF DOW, DHW AND DHWR TO BE CUT AND PREPARED TO BE REUSED FROM THIS POINT ONWARDS. SECTIONS SHOWN IN HIDDEN LINES ARE TO BE REMOVED. SEE NEW LAYOUT FOR NEW PIPING.
- 5 EXISTING BACK FLOW PREVENTER FOR THE MAIN DOW (FIRE PROTECTION SIDE) CLEAN EQUIPMENT AND VERIFY CONDITION.

[illegible]

Architecture

 **J.L. Richards**
ENGINEERS - ARCHITECTS - PLANNERS
www.jlrichards.ca

Structure

Seal



Drawing n°	Revision
------------	----------

MD-200	0
--------	---

THIS DRAWING IS ISSUED FOR DEMOLITION PURPOSES, IT REPRESENTS AN INVENTORY OF THE MAIN EXISTING INSTALLATIONS, GENERALLY VERIFIED IN CONNECTION WITH THE MODIFICATIONS SHOWN ON THIS DRAWING'S "MODIFIED" VERSION, AND OF WHICH THE GENUINE CONDITIONS MUST BE OBSERVED ON THE SITE BY THE CONTRACTOR.

