


BASEMENT GROUND FLOOR

GENERAL NOTE(S):

1- ALL EXISTING DUCTS TO BE REMOVED.

IDENTIFICATION(S):

- ALL EXISTING CONDUITS ARE TO BE REMOVED C/W RISERS GOING DOWN OR UP. EXISTING HOLES TO REMAIN FOR PASSAGE OF NEW AIR DISTRIBUTION, SEE MODIFIED DRAWINGS.
- 2 EXISTING GRILLE OPENINGS TO BE REUSED. SEE NEW LAYOUT
- EXISTING AIR HANDLING UNIT C/W WEATHER HOODS (CURRENTLY SITTING ON THE GROUND) TO BE RELOCATED ON NEW HOUSEKEEPING PAD. SEE NEW LAYOUT FOR NEW POSITION OF UNIT.



Description

0	2018-06-01	FOR TENDER
-		

△ REVIEW

Nº Date







THIS DRAWING IS ISSUED FOR DEMOLITION PURPOSES, IT REPRESENTS AN INVENTORY OF THE MAIN EXISTING INSTALLATIONS,

GENERALLY VERIFIED IN CONNECTION WITH

DRAWING'S "MODIFIED" VERSION, AND OF WHICH THE GENUINE CONDITIONS MUST BE

OBSERVED ON THE SITE BY THE CONTRACTOR.

MAISON DE DE LA FRANCOPHONIE D'OTTAWA

2720 RICHMOND ROAD, OTTAWA

MECHANICAL VENTILATION BASEMENT & GROUND FLOOR DEMOLITION

2018-06-01 1/8" = 1'-0"

Drawing n⁰

MD-400