



SUPPLEMENTAL INSTRUCTION

CONTRACTOR:
Tal-Co Building Innovations
4728 Bank Street, Suite A
Ottawa, ON, K1T 3W7
Attention: **Farah Bano**

PROJ.: **Turnbull School Music Room Addition**
PROJ. No.: 1705
DATE: October 18, 2018
S.I. No. **S.I. - 001**

Supplemental Instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract. Should the Contractor require a change in the contract price or project schedule, he shall submit to the Architect within ten (10) days of the date hereof, an itemized proposal. If the proposal is accepted by the Client, this Supplemental Instruction will be superseded by a Change order.

Partners

Barry J. Hobin
OAA, FRAIC, Hon. Fellow AIA

William A. Davis
OAA, MRAIC, Associate AIA

Gordon Lorimer
OAA, FRAIC, Associate AIA

Wendy Brawley
OAA, MRAIC, Associate AIA

Douglas Brooks
Senior Arch. Tech.

Directors

Marc Thivierge
OAA, MRAIC

Reinhard Vogel
Senior Arch. Tech.

Associates

Bryan Bonell
OAA, MRAIC, Associate AIA

William Ritcey
MRAIC

Dan Henhoeffter
Senior Arch. Tech.

1.1 TITLE

Fire Separations Clarification

1.2 REFERENCE

Issued for Construction Drawings – October 12, 2018
ASK-003
CIR #4

1.3 DESCRIPTION OF THE WORK

- .1 Refer to the attached **Architectural Sketch ASK-003** for clarification on new and existing fire separations within Music Room Addition and throughout the existing school.
- .2 Provide a 45-mins FRR between the existing school and the new Music Room addition per the attached sketch. Fire separation to extend from ground floor slab to underside of roof deck.
- .3 Extend fire separation min. 3.0m at each end wall of Music Room Addition as shown (Grids 1 & 6).

1.4 ATTACHMENTS

ASK-003

1.5 REASON

Clarification / OBC Requirement

Hobin Architecture Incorporated

63 Pamilla Street
Ottawa, Ontario
Canada K1S 3K7

t 613-238-7200
f 613-235-2005

hobinarc.com

Distribution:

- | | | | | |
|--|--|-------------------------------------|----------------------------------|--------------------------------------|
| <input checked="" type="checkbox"/> Owner | <input type="checkbox"/> City Authority | <input type="checkbox"/> Electrical | <input type="checkbox"/> Struct. | <input type="checkbox"/> Landscaping |
| <input checked="" type="checkbox"/> Contractor | <input checked="" type="checkbox"/> File | <input type="checkbox"/> Mech. | <input type="checkbox"/> Civil | <input type="checkbox"/> Other |

