



# SUPPLEMENTAL INSTRUCTION

CONTRACTOR:  
Tal-Co Building Innovations  
4728 Bank Street, Suite A  
Ottawa, ON, K1T 3W7  
Attention: Farah Bano

PROJ.: Turnbull School Music  
Room Addition  
PROJ. No.: 1705  
DATE: January 7, 2019  
S.I. No. S.I. - 007

Supplemental Instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract. Should the Contractor require a change in the contract price or project schedule, he shall submit to the Architect within ten (10) days of the date hereof, an itemized proposal. If the proposal is accepted by the Client, this Supplemental Instruction will be superseded by a Change order.

## Partners

Barry J. Hobin  
OAA, FRAIC, Hon. Fellow AIA

William A. Davis  
OAA, MRAIC, Associate AIA

Gordon Lorimer  
OAA, FRAIC, Associate AIA

Wendy Brawley  
OAA, MRAIC, Associate AIA

Douglas Brooks  
Senior Arch. Tech.

## Directors

Marc Thivierge  
OAA, MRAIC

Reinhard Vogel  
Senior Arch. Tech.

## Associates

Bryan Bonell  
OAA, MRAIC, Associate AIA

William Ritcey  
MRAIC

Dan Henhoeffler  
Senior Arch. Tech.

## Hobin Architecture Incorporated

63 Pamilla Street  
Ottawa, Ontario  
Canada K1S 3K7

t 613-238-7200  
f 613-235-2005

[hobinarc.com](http://hobinarc.com)

## 1.1 TITLE

Expansion Joint at xB

## 1.2 REFERENCE

Section Details A4.05  
Plan Details A6.02  
CIR #21

## 1.3 DESCRIPTION OF THE WORK

- .1 Refer to the attached Architectural Sketch SI-007.01 for revised section details for clarification of continuous prefin. bent metal expansion flashing at grid line xB.
- .2 Refer to the attached Architectural Sketch SI-007.02 for revised plan details to show caulking locations and a minimum 25mm clearance between new and existing wall structural elements.

## 1.4 ATTACHMENTS


SI-007.01 – Expansion Joints at Section Details 5 & 6/A4.05  
SI-007.02 – Expansion Joints at Plan Details 3 & 12/A6.02

## 1.5 REASON


Clarification

Distribution:


- |                                                |                                          |                                     |                                  |                                      |
|------------------------------------------------|------------------------------------------|-------------------------------------|----------------------------------|--------------------------------------|
| <input checked="" type="checkbox"/> Owner      | <input type="checkbox"/> City Authority  | <input type="checkbox"/> Electrical | <input type="checkbox"/> Struct. | <input type="checkbox"/> Landscaping |
| <input checked="" type="checkbox"/> Contractor | <input checked="" type="checkbox"/> File | <input type="checkbox"/> Mech.      | <input type="checkbox"/> Civil   | <input type="checkbox"/> Other       |




**1** SI-007 - DETAIL 5/A4.05  
 SI-007.01 SCALE: 1 : 5




**2** SI-007 - DETAIL 6/A4.05  
 SI-007.01 SCALE: 1 : 10

 <p><b>HOBIN</b> ARCHITECTURE</p>	PROJECT/LOCATION: TURNBULL SCHOOL MUSIC ROOM ADDITION 1132 FISHER AVE. OTTAWA, ON	DRAWING NAME: EXPANSION JOINTS AT SECTION DETAILS 5 & 6/A4.05	DATE: 01/07/19	SCALE: As indicated
	Hobin Architecture Incorporated 63 Pamilla Street T: 613-238-7200 Ottawa, ON K1S 3K7 F: 613-235-2005 hobinarc.com E: mail@hobinarc.com	PROJECT NO.: 1705	ASK No. SI-007.01	



1 SI-007 - DETAIL 3/A6.02  
SI-007.02 SCALE: 1 : 10



2 SI-007 - DETAIL 12/A6.02  
SI-007.02 SCALE: 1 : 10



PROJECT/LOCATION:  
TURNBULL SCHOOL MUSIC  
ROOM ADDITION  
1132 FISHER AVE. OTTAWA, ON

**Hobin Architecture Incorporated**  
63 Pamilla Street T: 613-238-7200  
Ottawa, ON K1S 3K7 F: 613-235-2005  
hobinarc.com E: mail@hobinarc.com

DRAWING NAME:  
EXPANSION JOINTS AT PLAN  
DETAILS 3 & 12/A6.02

DATE:  
01/07/19

SCALE:  
1 : 10

PROJECT NO.:  
1705

ASK No.  
SI-007.02