

SUPPLEMENTAL INSTRUCTION



CONTRACTOR:
Tal-co Building Innovations Ltd.
Suite A, 4728 Bank Street
Ottawa, ON K1T 3W7

PROJ.: Meridian Community
Building Rebuild
PROJ. No.: 1841
DATE: June 20, 2019
S.I. No. S.I. – A001

Supplemental Instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract. Should the Contractor require a change in the contract price or project schedule, he shall submit to the Architect within ten (10) days of the date hereof, an itemized proposal. If the proposal is accepted by the Client, this Supplemental Instruction will be superseded by a Change order.

1.1 TITLE

Window and Door Clarifications

1.2 REFERENCE

Contractor's Information Request No. 05
Architectural Drawing A3.01 Elevations & Window Schedule
Architectural Drawing A9.01 Door & Finish Schedules

1.3 DESCRIPTION OF THE WORK

- .1 Window dimensions in the Links can be adjusted to match the actual window openings – coordinate sizes with window supplier.
- .2 Windows W43, W44, W45 and W46 are to have the same vertical dimension (to suit 2160 MO as shown on Section 1/A4.2). Coordinate rough opening size with window supplier.
- .3 Revise Doors 117.1 and 118.1 to insulated metal doors c/w single glass cut-outs in thermally broken steel frames to accommodate the panic bars. Adjust other hardware to suit (include revised hardware in shop drawing submission).

1.4 ATTACHMENTS

N/A

1.5 REASON

Site conditions.

Partners

Barry J. Hobin
OAA, FRAIC, Hon. Fellow AIA

William A. Davis
OAA, MRAIC, Associate AIA

Gordon Lorimer
OAA, FRAIC, Associate AIA

Wendy Brawley
OAA, MRAIC, Associate AIA

Douglas Brooks
Senior Arch. Tech.

Directors

Marc Thivierge
OAA, MRAIC

Reinhard Vogel
Senior Arch. Tech.

Associates

Bryan Bonell
OAA, MRAIC, Associate AIA

William Ritcey
MRAIC

Dan Henhoeffler
Senior Arch. Tech.

Hobin Architecture Incorporated

63 Pamilla Street
Ottawa, Ontario
Canada K1S 3K7

t 613-238-7200
f 613-235-2005

hobinarc.com

Distribution:

- | | | | | |
|--|--|-------------------------------------|----------------------------------|--------------------------------------|
| <input checked="" type="checkbox"/> Owner | <input type="checkbox"/> City Authority | <input type="checkbox"/> Electrical | <input type="checkbox"/> Struct. | <input type="checkbox"/> Landscaping |
| <input checked="" type="checkbox"/> Contractor | <input checked="" type="checkbox"/> File | <input type="checkbox"/> Mech. | <input type="checkbox"/> Civil | <input type="checkbox"/> Other |