


1 Meridian Place - The Meridian Retirement Community - Fire Restoration

Disconnect Switch

	
GOODKEY, WEEDMARK & ASSOCIATES LIMITED Consulting Engineers 1688 Woodward Dr., Ottawa, ON Canada K2C 3R8 Tel.: 613-727-5111, Fax: 613-727-5115, info@gwal.com	
REVIEWED <input type="checkbox"/>	REVISE & RESUBMIT <input type="checkbox"/>
REVIEWED AS NOTED <input checked="" type="checkbox"/>	REJECTED <input type="checkbox"/>
For general conformance only. Contractor remains responsible for equipment & system details, performance, accuracy, dimensions and coordination.	Date: June 24, 2019
	GWA #: 2019-148
	SD #: SE20
	By: M.Trottier

- Disconnect switch to be weather proof



LAMARCHE ELECTRIC INC.

REVIEWED: 2019-07-18

REVIEWED BY: Daniel Denis

ECRA/ESA License 7002052

Main

Product	Single Throw Safety Switch
Disconnect Type	Non-fusible disconnect
Number of Poles	3
Electrical Connection	Lugs
Duty Rating	Heavy duty

Complementary

Line Rated Current	100 A
Factory Installed Neutral	None
Mounting Type	Surface
System Voltage	600 V AC/DC
Wire Size	AWG 14...AWG 10 (copper) AWG 12...AWG 1/0 (aluminium)

Environment

Certifications	CSA
Enclosure Rating	NEMA 1 galvanized steel

Offer Sustainability

Sustainable offer status	Green Premium product
RoHS (date code: YYWW)	Compliant - since 1313 - Schneider Electric declaration of conformity Schneider Electric declaration of conformity
REACH	Reference not containing SVHC above the threshold Reference not containing SVHC above the threshold
Product environmental profile	Available
Product end of life instructions	Need no specific recycling operations

Disclaimer: This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications