

# CONTEMPLATED CHANGE ORDER



CONTRACTOR:  
Tal-co Building Innovations Ltd.  
Suite A, 4728 Bank Street  
Ottawa, ON K1T 3W7

PROJ.: Meridian Community  
Building Rebuild  
PROJ. No.: 1841  
DATE: Nov. 28, 2019  
C.C.O. No. 037

Pursuant to GC 6.2 – Change Orders in CCDC 2 – 2008, the following items are proposed changes to the contract for this project. Unless noted below, work is not to proceed until authorized by a Change Order. All material and workmanship are to be as described in the contract documents unless otherwise stated. Please submit an itemized quotation for changes to the contract value and/or to the project schedule, within 10 calendar days of the date hereon.

**37.1 TITLE**  
Relocate Exterior Exit Lights at Links

**37.2 REFERENCE**  
Electrical SI-E4

**37.3 DESCRIPTION OF WORK**  
.1 Refer to the attached Electrical Site Instruction SI-E4 by Goodkey Weedmark & Associates Limited for the electrical requirements of this CCO.

**37.4 ATTACHMENTS**  
Electrical SI-E4

**37.5 REASON**  
Authority having Jurisdiction.

## Partners

Barry J. Hobin  
OAA, FRAIC, Hon. Fellow AIA

William A. Davis  
OAA, MRAIC, Associate AIA

Gordon Lorimer  
OAA, FRAIC, Associate AIA

Wendy Brawley  
OAA, MRAIC, Associate AIA

Douglas Brooks  
Senior Arch. Tech.

## Directors

Marc Thivierge  
OAA, MRAIC

Reinhard Vogel  
Senior Arch. Tech.

## Associates

Bryan Bonell  
OAA, MRAIC, Associate AIA

William Ritcey  
MRAIC

Dan Henhoeffler  
Senior Arch. Tech.

A handwritten signature in black ink that reads "Bryan Bonell".

Bryan Bonell

## Hobin Architecture Incorporated

63 Pamilla Street  
Ottawa, Ontario  
Canada K1S 3K7

t 613-238-7200

f 613-235-2005

[hobinarc.com](http://hobinarc.com)



PROJECT - **1 MERIDIAN PLACE – THE MERIDIAN RETIREMENT COMMUNITY  
FIRE RESTORATION**

CONTRACTOR - LAMARCHE ELECTRIC INC.

PROJECT NO. - GWA 2019-148

DATE - NOVEMBER 27, 2019

SI NO. - SI-E4

SI TITLE - EXIT SIGN LOCATION

**PAGE 1 OF 1**

---

A site instruction is issued only for the purposes of recording any clarifications or interpretations of the contract documents for the purpose of giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and are issued with the understanding that they do not affect the contract price or the construction completion date.

---

**1. Reference Drawing E3:**

- .1 Locate exterior weatherproof exit sign above canopy in order to be visible on approach to the exit door.

---

Issued by: Marc Trottier /cb

Distribution:

Bryan Bonell (Hobin Architecture Incorporated)  
Robert Brand (MBC Group Ltd.)  
Francis W.A. Bann (GWA – Mechanical)  
Derek Kennedy (GWA – Mechanical)  
Antoine Mikhaïel (GWA – Electrical)  
Liam Beck (GWA – Electrical)  
Yves Lavictoire (GWA – Electrical)