



F L Y N N
ARCHITECT INC.

ADDENDUM

ADDENDUM NO: **05**

CLIENT: **Mr. Ryan Firlotte,**
2300 Stevenage Drive
Ottawa, ON
K1G 3W3

PROJECT NAME: **Enterprise Palladium**
225 Huntmar
Ottawa, Ontario

PROJECT NO: 15-010
DATE: Dec. 06, 2019

REASON FOR CHANGE: Clarification to documents

- 1. Barrier free washroom sink: Wall mounted lavatory Zurn M# Z-5341
- 2. HWT Reliance 6 Gal, 120V, 1Ph, 1500W
- 3. 1 " dia. water meter shall be approved by City Of Ottawa, water department

END OF ADDENDUM

PER.....
Jason C. Flynn, OAA, MRAIC
Flynn Architect Inc.
Email: j.flynn@flynnarchitect.com

DISTRIBUTION: as above