



F L Y N N

ARCHITECT INC.

SITE INSTRUCTION

SIN NO: **25**
 CONTRACTOR: **Mr. Pat Newton**
Talco Building Innovations Inc.
 4728 Bank Street
 Ottawa ON K1T 3W7

CLIENT: **Mr. Ryan Firlotte**
 Enterprise Holdings
 Group Property Developemnt & Facilities Specialist
 2300 Stevenage Dr.
 Ottawa ON K1G 3W3

PROJECT NAME: **225 Huntmar**
Ottawa, Ontario

PROJECT NO: 15-010
 DATE: 2020, Jun. 18

The following items are proposed changes to the contract documents previously issued for this project. Unless noted below, work is not to proceed until authorized by a change order. All material and workmanship are to be as described in the contract documents unless otherwise stated. Please submit an itemized quotation for changes to the tender price and/or to the project schedule, and within 5 calendar days of the date hereon.

REASON FOR CHANGE: **Contractor Request / Site Coordination**

1. Further to Contractor's Information Request #25 dated 2020 Jun. 18.
 Install radiant heaters at 10' aff for car wash bay. Radiant heaters for truck wash bay to remain per the owner's specifications at min. 11 ft. aff to clear cube van height.

END OF SITE INSTRUCTION

PER.....
 Jason C. Flynn, OAA, MRAIC
 Jason C. Flynn Architect Inc.
 Email: j.flynn@flynnarchitect.com

DISTRIBUTION: as above

