

# ADDENDUM



Project: Arlington Woods Free  
Methodist Church Renovation

Addendum No.: A02

Tender # N/A

No. of Pages: 2 (including cover page)

Project # 1846

Date: August 10, 2020

---

The following change(s) in the Tender Documents are effective immediately.  
This Addendum forms part of the Contract Documents.

Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form.  
Failure to do so may subject bidder to disqualification.

## Item Description

- 1.1 Incorporate Changes identified in Architectural Addendum A2 (1 page) prepared by Hobin Architecture Incorporated and attached.

### Partners

Barry J. Hobin  
OAA, FRAIC, Hon. Fellow AIA

William A. Davis  
OAA, MRAIC, Associate AIA

Gordon Lorimer  
OAA, FRAIC, Associate AIA

Wendy Brawley  
OAA, MRAIC, Associate AIA

Douglas Brooks  
Senior Arch. Tech.

### Directors

Marc Thivierge, OAA

Reinhard Vogel

### Associates

Bryan Bonell, OAA

William Ritcey

Dan Henhoeffler

Melanie Lamontagne, OAA

Rheal Labelle

Patrick Bisson, OAA

### Hobin Architecture Incorporated

63 Pamilla Street  
Ottawa, Ontario  
Canada K1S 3K7

t 613-238-7200

f 613-235-2005

[hobinarc.com](http://hobinarc.com)



The following information supplements and/or supersedes the bid documents.

This addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supplements and/or supercede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof.

Item No.	Drawing or Spec Section	Description
<b>A1.1 General</b>		
A1.1.1	A2.03 E7	<b><u>Mixed Use Space 018 – Electrical &amp; Ceiling Plan:</u></b> Allow for 20m (65') of 19mm dia. (3/4") conduit for future A/V within Mixed-Use Space ceiling assembly. Conduit to be placed within fire-rated ceiling assembly. Seal all penetrations through fire-rated gypsum board membrane with ULC-labelled fire-rated caulking.
A1.1.2	A2.03 E7	<b><u>Mixed Use Space 018 – Electrical &amp; Ceiling Plan:</u></b> Allow for six (6) fire-rated access panels to be located within fire rated ceiling assembly in Mixed-Use Space. 300x300mm, locations to suit junction boxes. Coordinate locations of junction boxes with new lighting layout to ensure access panels do not interfere with surface mounted light fixtures. Coordinate layout with Architect prior to installation.

**Partners**

- Barry J. Hobin  
OAA, FRAIC, Hon. Fellow AIA
- William A. Davis  
OAA, MRAIC, Associate AIA
- Gordon Lorimer  
OAA, FRAIC, Associate AIA
- Wendy Brawley  
OAA, MRAIC, Associate AIA
- Douglas Brooks  
Senior Arch. Tech.

**Directors**

- Marc Thivierge, OAA
- Reinhard Vogel

**Associates**

- Bryan Bonell, OAA
- William Ritcey
- Dan Henhoeffler
- Melanie Lamontagne, OAA
- Rheal Labelle
- Patrick Bisson, OAA

END OF ADDENDUM

**Hobin Architecture Incorporated**

63 Pamilla Street  
 Ottawa, Ontario  
 Canada K1S 3K7

t 613-238-7200  
 f 613-235-2005