



**CARLETON PLACE ARENA
ADDITION AND RENOVATIONS
75 Neelin Street Carleton Place, Ontario**

TAL-CO Building Innovations Limited
4728 Bank Street, Suite A
Gloucester, Ontario K1T 3W7
Tel: 613-821-3959
Fax: 613-821-2938

Issue date: 19-Aug-20
Revision date: N/A
Revision #: N/A

CIR #1 Detailed Summary

Questions:

1. Please provide schedule and/or specifications for the Expansion Tanks.

End of CIR No. 1

SITE INSTRUCTION NO. ME-02
MECHANICAL AND ELECTRICAL

Project Name: Carleton Place Arena
75 Neelin Street
Carleton Place, Ontario

Project No.: 205

Date: 2020 September 14

RESPONSE TO CIR#1

MECHANICAL

- M2.1 Expansion Tank at Water Entry:
Expansion Size: 10 US gal
Model: AMTROL Partial Acceptance Bladder ST Series ASME
or approved equal
- M2.2 Expansion Tank at Water Heater:
Expansion Size: 35 US gal
Model: AMTROL Diaphragm ST-C Series ASME
or approved equal

M. Morris P.Eng.