

LARRY GAINES • ARCHITECT

Old Town Hall
14 Bridge Street, PO 706
Almonte, Ontario
K0A 1A0

T: 613-256-3630
gaines@bellnet.ca

CIR Response

CIR #14

To:

TALCO BUILDING INNOVATIONS LTD.
4728 Bank Street, Suite A
Ottawa, Ontario

Project:

Carleton Place Arena
Renovation and Addition

Date:

September 24, 2020

CIR Responses are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract

REFERENCES:

CIR #14 submitted September 24, 2020

Please proceed with the installation of a back water valve at the weeping tile on a time and materials basis.

Thank you

PER: Larry Gaines
Architect



**CARLETON PLACE ARENA
ADDITION AND RENOVATIONS
75 Neelin Street Carleton Place, Ontario**

TAL-CO Building Innovations Limited
4728 Bank Street, Suite A
Tel: 613-821-3959
Fax: 613-821-2938

Issue date: Sept 24, 2020
Revision date:

CIR # 14 Detailed Summary

Questions:

Please refer to attached question from our Mechanical subtrade.

End of CIR No. 14



REQUEST FOR INFORMATION

DATE:	September 24, 2020
RFI #:	3
CW Job #:	C20-056

Project Name: **Carleton Place Arena**

Project Address: **75 Neelin St.**

In reference to the above contract, we are hereby requesting a clarification, determination and/or information concerning the following:

The current design does not show a back-water valve on the weeping tile.

Please see attached drawing for reference. The weeping tile needs a back-water valve. This valve has to be accessible, so the weeping tile needs to be brought into the building and tied into the storm service.

Please provide a CCN to cover the cost of the back-water valve and floor mounted access door.

Thanks,



Craig Calvank,

Project Manager

