

LARRY GAINES • ARCHITECT

Old Town Hall
14 Bridge Street, PO 706
Almonte, Ontario
K0A 1A0

T: 613-256-3630
gaines@bellnet.ca

CIR Response

CIR #47

To:

TALCO BUILDING INNOVATIONS LTD.
4728 Bank Street, Suite A
Ottawa, Ontario

Project:

Carleton Place Arena
Renovation and Addition

Date:

February 16, 2021

CIR Responses are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract

REFERENCES:

CIR #47 submitted February 9, 2021

As stated in this CIR

1. The cover plates are stainless,
2. The light switches are toggle type
3. The receptacles are duplex type
4. The colour of the switches and receptacles is white

PER:

Larry Gaines

Architect



**CARLETON PLACE ARENA
ADDITION AND RENOVATIONS
75 Neelin Street Carleton Place, Ontario**

TAL-CO Building Innovations Limited
4728 Bank Street, Suite A
Gloucester, Ontario K1T 3W7
Tel: 613-821-3959
Fax: 613-821-2938

Issue date: Feb- 09 - 2021
Revision date:
Revision #:

**CIR # 47
Receptacle and Switch Colors**

Please find below question from our electrical contractor

On the drawing E-001, 10.2.2.3 and 10.2.3.3, it is noted that the color of the receptacles and switches are to be selected by the owner and architect.

What colors would the owner and architect like to have so we can order our materials?

Keep in mind of two things, as per 10.2.4, cover plates are to be stainless steel, and the lighting control switches have already been approved and ordered which are all colored white except for the dimmer switch, with no motion, which comes with color change kit for white, ivory, and light almond.

Also, drawings do not specify style of switch for the non-dimmer or motions, so they will be of type "toggle" and not "Decora", as those come at a higher cost. As well, receptacles will be of type "Duplex" and not "Decora".

End of CIR No. 47