

## **SITE INSTRUCTION NO. ME-01** **MECHANICAL AND ELECTRICAL**

**Project Name:** Carleton Place Arena  
75 Neelin Street  
Carleton Place, Ontario

**Project No.:** 205

**Date:** 2020 September 09

---

### **MECHANICAL**

#### **M1.1 STORM DRAIN:**

Refer to attached sketch of storm drain prepared by Town of Carleton Place, with the following notes:

- Storm piping shall be 200mm to match existing;
- Supply and install cleanout at 90 degree turn, and at building exit.

New Roof Drains shall be deleted, as follows:

- 2 x 3" roof drains and 4" storm drain piping with insulation shall be deleted.
- Upper roof shall drain through scuppers, per the Architectural drawings.

M. Morris P.Eng.

