

LARRY GAINES • ARCHITECT

Old Town Hall
14 Bridge Street, PO 706
Almonte, Ontario
K0A 1A0

T: 613-256-3630
gaines@bellnet.ca

rec'd w/
response to
CIR # 20

Site Instruction #01

To: Talco Building Innovations Ltd.
4728 Bank Street, Suite A
Ottawa, Ontario, K1T 3W7

Project: Carleton Place Arena
Neelin Street

Date: Oct. 27, 2020

Site instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract. Should the contractor require a change in the contract price or project schedule, he shall submit to the architect within ten (10) days of the date hereof, an itemized proposal. If the proposal is accepted by the client, this site instruction will be superseded by a Change Order

REFERENCES:

Site visits of Oct. 26 and 27

GENERAL:

1. Ductwork shown in corridor on M102 is to feed into dressing rooms above bond beam between the C-channels.
2. Locate the plumbing vent stack in the corner of the corridor beside Grid Line 10 as opposed to in the adjacent shower room, as previously discussed.

PER: Larry Gaines
Architect

