

**SITE INSTRUCTION NO. ME-16**  
**MECHANICAL AND ELECTRICAL**

**Project Name:** Carleton Place Arena  
75 Neelin Street  
Carleton Place, Ontario

**Project No.:** 205  
**Date:** 2021 March 17

---

**MECHANICAL:**

**M16.1 WATER METER (CIR #54):**

- .1 Water meter shall be 3" size.

**ELECTRICAL:**

**E16.1 FIRE ALARM SYSTEM:**

- .1 Disconnect and remove the existing & obsolete relay, located above the existing Fire Alarm Control and Annunciator Panel.

(GBE Electric noted that, according to Rusty, this was used for Arena garage doors, and was disconnected for safety reasons).

M. Morris P.Eng.