

LARRY GAINES • ARCHITECT

Old Town Hall
14 Bridge Street, PO 706
Almonte, Ontario
K0A 1A0

T: 613-256-3630
gaines@bellnet.ca

Site Instruction #09

To: Talco Building Innovations Ltd.
4728 Bank Street, Suite A
Ottawa, Ontario, K1T 3W7

Project: Carleton Place Arena
Neelin Street

Date: April 06, 2021

Site instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract. Should the contractor require a change in the contract price or project schedule, he shall submit to the architect within ten (10) days of the date hereof, an itemized proposal. If the proposal is accepted by the client, this site instruction will be superseded by a Change Order

REFERENCES:

General Meeting 04-01-2021

GENERAL:

.1 The decision to use the CAFCO spray applied fire protection system on the steel structure of the second floor was approved in lieu of the original rated assembly. The approval is conditional upon the following conditions as outlined by the CBO.

- Written onfirmation that the system is considered acceptable for use in an Assembly / Office occupancy

- The work will be performed by a firm with expertise in the installation of fire protection materials and be recognized and approved by the manufacturer. Confirm accreditation and confirmation that the installation is adequate (fire resistance) and compliant with the installation requirements with respect to thickness and condition of substrate.

.2 A bulkhead above the kitchen millwork is no longer required, however, the raised ceilings at the exterior walls will be installed

.3 The fire dampers in the ductwork are now to be installed at the concrete floor slab

PER: _____
Larry Gaines
Architect