



REFER TO MD1.1 FOR CONTINUATION

NOTE 1:
 BYPASS CIRCUIT BALANCING VALVE SHALL BE ADJUSTED TO PROVIDE EQUIVALENT PRESSURE DROP TO THE COIL AT FULL BYPASS CONDITIONS.

NOTE 2:
 REFER TO SCHEDULE FOR FLOW TO EACH TERMINAL HEATER.

1 HYDRONIC HEATING SCHEMATIC
 M301 SCALE: N.T.S.

WITH REFERENCE TO M301

<p>1345 ROSEMOUNT AVENUE CORNWALL, ONTARIO CANADA K6J 3E5 PHONE: 613-933-5602 FAX: 613-936-0335 WWW.WSP.COM</p>	PROJECT:	NORTH GRENVILLE POOL HOUSE	SCALE: AS INDICATED
	TITLE:	HYDRONIC HEATING SYSTEMS LAYOUT HYDRONIC HEATING SCHEMATIC	DATE: JULY 2022
			PROJECT NO: 211-09894-00
			DRAWING NO: MD1.2

M:\2021\211-09894-00 - Riverside Park Outdoor Play Project\14.0 Mech\dwg\NGPH_MECH.dwg Jul 13, 2022-9:04pm BY: (Patrick.mckee)