



ADDENDUM No. 6
REQUEST FOR PROPOSAL (RFP) FOR
PRC 22-12 – Municipality of North Grenville Pool House

Date of Addendum No. 6

Issued: July 20, 2022

Addendum Issued By:

Mark Guy
Director of Parks, Recreation & Culture
613-258-9569 ext. 107
mguy@northgrenville.on.ca

The Request for Proposals (RFP) is modified as set forth in this Addendum. The original RFP documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the RFP. Respondent shall take this Addendum into consideration when preparing and submitting its Proposal.

Purpose of Addendum:

The purpose of this Addendum is to provide guidance re: light fixture wiring:

NOTE: **The use of AC-90 (BX) wiring is acceptable for light fixtures, with daisy chain installation in the drywall ceiling space to avoid installation of access panels at each fixture.**

Please include a signed (below) copy of this addendum in its entirety in each proposal submission.

Company

Company Representative

Date (DD/MM/YYYY)